

State of New Jersey  
Department of Children and Families  
Office of Licensing

**DRINKING WATER TESTING STATEMENT OF ASSURANCE**

• PROGRAMS IN OPERATING PUBLIC SCHOOLS ARE NOT REQUIRED TO COMPLETE THIS FORM •

Name of Child Care Center: Carolyn Stokes Day Nursery		License ID: 11CAR0002
Site Address (Building # and Street): 1 Princess Diana Lane		
Municipality: Trenton	County: Mercer	
Sponsor/Sponsor Representative: Rosemarie Smith		Phone #: 609-392-2648
Sponsor/Sponsor Representative Email: office@carolynstokes.org		
Additional Contact Person: Joseph Pizzano		Phone #: 609-392-2648
Title: Executive Director	Email: director@carolynstokes.org	

1. The center, as described above, has reviewed the MANUAL OF REQUIREMENTS FOR CHILD CARE CENTERS requiring testing for lead and copper in drinking water and provides assurance that the development and implementation of a testing program was completed in accordance with N.J.A.C. 3A:52-5.3(i)5i as evidenced by our completion of the attached Drinking Water Testing Checklist.
2. The center, as described above, provided all notifications of test results consistent with the requirements of this subchapter.
3. The center, as described above, will continue to fully implement the requirements of this subchapter, including the continuance of any actions taken in response to a lead or copper action level exceedance (e.g., continue to provide bottled water and/or maintain any remedial measure or treatment unit).

**CERTIFICATION:** By signing below, the **Sponsor or Sponsor Representative** certifies that all statements above are true and accurate:

Sponsor/Sponsor Representative: (PRINT)	Rosemarie Smith
Signature:	Rosemarie Smith
Signature Date:	1/6/2022

Sample Date 12/03/2021

	Source	Results Lead	Results Copper	Units	Pos/Neg
1-1	Outlet 2	3.5	29.6	ug/L	Neg.
1-2	Outlet 4	7.4	25.2	ug/L	Neg.
1-3	Outlet 6	4.5	34.1	ug/L	Neg.
1-4	Outlet 8	3.1	35.4	ug/L	Neg.
1-5	Outlet 10	3.4	31.4	ug/L	Neg.
1-6	Outlet 11	3.7	22.7	ug/L	Neg.
1-7	Outlet 13	3.5	50.9	ug/L	Neg.
1-8	Outlet 15	1.1	110	ug/L	Neg.
1-9	Outlet 17	3.8	230	ug/L	Neg.
1-10	Outlet 18	2.6	186	ug/L	Neg.

There are no water fountains or coolers in the child care. The laboratory results show that none of the samples were found to exceed the lead in drinking water action level of 15 ug/L and copper 1,300 ug/L. Sampling forms and diagram are attached.

Sampling Performed by: Darren Slack  
NJ Lead Inspector/Risk Assessor  
Mandell Environmental Consulting  
409 Minnisink Road, Suite 102  
Totowa, NJ 07512

Signed: Darren Slack Date: 12-31-2021